



State of Louisiana  
Louisiana Department of Health  
Public Health Laboratories  
104 North First Street  
Amite, LA 70422  
985-748-2011  
<http://www.dhh.la.gov/lab>



April 20, 2021

The following analytical results have been obtained for the indicated sample(s) which was submitted to this laboratory:

---

<b>Public Water System:</b>	LA1103053	<b>Sample ID:</b>	A2102105-001
	ST TAM PARISH - CROSS GATES SD	<b>Sample type:</b>	Routine
<b>PWS facility:</b>	DS0950	<b>DISTRIBUTION SYSTEM</b>	
<b>Sampling location:</b>	TCR-007	<b>1059 PARKPOINT DR.</b>	
<b>Collection address:</b>		<b>Sample collector:</b>	LAQUANDA JACKSON
<b>Free chlorine (mg/L):</b>	0.11	<b>Collection date:</b>	4/19/2021 11:35:00AM
<b>Total chlorine (mg/L):</b>	1.66	<b>Lab submittal date:</b>	4/19/2021 1:43:00PM

---

Component Name	Results	Units	MCL
<b>Coliforms - Presence/Absence</b>			
Total Coliform	Absent	N/A	N/A
E. Coli	Absent	N/A	N/A

---

<b>Public Water System:</b>	LA1103053	<b>Sample ID:</b>	A2102105-002
	ST TAM PARISH - CROSS GATES SD	<b>Sample type:</b>	Routine
<b>PWS facility:</b>	DS0950	<b>DISTRIBUTION SYSTEM</b>	
<b>Sampling location:</b>	TCR-008	<b>500 DOCKSIDE DR.</b>	
<b>Collection address:</b>		<b>Sample collector:</b>	LAQUANDA JACKSON
<b>Free chlorine (mg/L):</b>	0.11	<b>Collection date:</b>	4/19/2021 11:52:00AM
<b>Total chlorine (mg/L):</b>	1.69	<b>Lab submittal date:</b>	4/19/2021 1:43:00PM

---

Component Name	Results	Units	MCL
<b>Coliforms - Presence/Absence</b>			
Total Coliform	Absent	N/A	N/A
E. Coli	Absent	N/A	N/A

<b>Public Water System:</b>	LA1103053 ST TAM PARISH - CROSS GATES SD	<b>Sample ID:</b>	A2102105-003
<b>PWS facility:</b>	DS0950 DISTRIBUTION SYSTEM	<b>Sample type:</b>	Routine
<b>Sampling location:</b>	TCR-013 40145 TAYLOR TRACE	<b>Sample collector:</b>	LAQUANDA JACKSON
<b>Collection address:</b>		<b>Collection date:</b>	4/19/2021 10:44:00AM
<b>Free chlorine (mg/L):</b>	0.07	<b>Lab submittal date:</b>	4/19/2021 1:43:00PM
<b>Total chlorine (mg/L):</b>	1.87		

Component Name	Results	Units	MCL
<b>Coliforms - Presence/Absence</b>			
Total Coliform	Absent	N/A	N/A
E. Coli	Absent	N/A	N/A

<b>Public Water System:</b>	LA1103053 ST TAM PARISH - CROSS GATES SD	<b>Sample ID:</b>	A2102105-004
<b>PWS facility:</b>	DS0950 DISTRIBUTION SYSTEM	<b>Sample type:</b>	Routine
<b>Sampling location:</b>	TCR-014 102 CEDARWOOD DR.	<b>Sample collector:</b>	LAQUANDA JACKSON
<b>Collection address:</b>		<b>Collection date:</b>	4/19/2021 11:03:00AM
<b>Free chlorine (mg/L):</b>	0.16	<b>Lab submittal date:</b>	4/19/2021 1:43:00PM
<b>Total chlorine (mg/L):</b>	2.0		

Component Name	Results	Units	MCL
<b>Coliforms - Presence/Absence</b>			
Total Coliform	Absent	N/A	N/A
E. Coli	Absent	N/A	N/A

<b>Public Water System:</b>	LA1103053 ST TAM PARISH - CROSS GATES SD	<b>Sample ID:</b>	A2102105-005
<b>PWS facility:</b>	DS0950 DISTRIBUTION SYSTEM	<b>Sample type:</b>	Routine
<b>Sampling location:</b>	TCR-017 505 CROSSGATES BLVD.	<b>Sample collector:</b>	LAQUANDA JACKSON
<b>Collection address:</b>		<b>Collection date:</b>	4/19/2021 11:19:00AM
<b>Free chlorine (mg/L):</b>	0.11	<b>Lab submittal date:</b>	4/19/2021 1:43:00PM
<b>Total chlorine (mg/L):</b>	2.01		

Component Name	Results	Units	MCL
<b>Coliforms - Presence/Absence</b>			
Total Coliform	Absent	N/A	N/A
E. Coli	Absent	N/A	N/A

Reviewed by: Dat Ngo