

Cross Gates Water System (PWS 1103053)

12.5% Sodium Hypochlorite

Steele Road Well Feed Rate: 170 ml/min

Willow Wood Well Feed Rate: 140 ml/min

Date	Sample Location	Free Chlorine (mg/L)	Total Chlorine (mg/L)	Monochloramine (mg/L)	Free Ammonia (mg/L)
3/26/18	POE 001	0.12	2.31		
3/26/18	MRT 002	0.19	2.13		
3/26/18	POE 003	0.3	2.02		
3/26/18	TCR 004	0.18	1.22		
3/26/18	TCR 005	0.19	1.92		
3/26/18	TCR 006	0.19	2.12		
3/26/18	TCR 007	0.19	2.11		
3/26/18	TCR 008	0.22	2.06		
3/26/18	TCR 009	0.2	2.11		
3/26/18	TCR 010	0.19	1.73		
3/26/18	TCR 011	0.19	2.18		
3/26/18	TCR 012	0.25	2.04		
3/26/18	TCR 013	0.2	1.98		
3/26/18	TCR 014	0.22	2.09		
3/26/18	TCR 015	0.21	2.04		
3/26/18	TCR 016	0.15	1.56		
3/26/18	TCR 017	0.28	2.15		
3/26/18	ACR 018	0.17	1.73		
3/26/18	ACR 019	0.23	1.6		
3/26/18	ACR 020	0.29	2.28		
3/27/18	POE 001	0.22	2.43		

3/27/18	MRT 002	0.24	2.14		
3/27/18	POE 003	0.32	2.43		
3/27/18	TCR 004	0.15	1.97		
3/27/18	TCR 005	0.45	2.18		
3/27/18	TCR 006	0.22	2.01		
3/27/18	TCR 007	0.1	1.82		
3/27/18	TCR 008	0.24	2.01		
3/27/18	TCR 009	0.21	1.82		
3/27/18	TCR 010	0.17	1.79		
3/27/18	TCR 011	0.21	2.21		
3/27/18	TCR 012	0.22	2.09		
3/27/18	TCR 013	0.2	1.83		
3/27/18	TCR 014	0.24	2.01		
3/27/18	TCR 015	0.18	2.03		
3/27/18	TCR 016	0.17	1.94		
3/27/18	TCR 017	0.25	2.21		
3/27/18	ACR 018	0.18	1.76		
3/27/18	ACR 019	0.21	1.82		
3/27/18	ACR 020	0.27	2.02		
3/28/18	POE 001	0.3	2.18		
3/28/18	MRT 002	0.19	2.01		
3/28/18	POE 003	0.29	2.3		
3/28/18	TCR 004	0.17	1.39		
3/28/18	TCR 005	0.15	2.08		
3/28/18	TCR 006	0.2	1.95		
3/28/18	TCR 007	0.13	1.92		
3/28/18	TCR 008	0.2	1.29		
3/28/18	TCR 009	0.22	1.79		
3/28/18	TCR 010	0.16	1.43		
3/28/18	TCR 011	0.1	1.19		
3/28/18	TCR 012	0.12	1.09		

3/28/18	TCR 013	0.17	1.57		
3/28/18	TCR 014	0.12	0.87		
3/28/18	TCR 015	0.16	1.73		
3/28/18	TCR 016	0.13	1.11		
3/28/18	TCR 017	0.23	2.05		
3/28/18	ACR 018	0.15	1.29		
3/28/18	ACR 019	0.21	1.99		
3/28/18	ACR 020	0.22	2.07		
3/29/18	POE 001	0.28	2.48		
3/29/18	MRT 002	0.11	1.15		
3/29/18	POE 003	0.25	2.26		
3/29/18	TCR 004	0.28	2.37		
3/29/18	TCR 005	0.25	1.96		
3/29/18	TCR 006	0.17	1.56		
3/29/18	TCR 007	0.12	1.01		
3/29/18	TCR 008	0.49	2.32		
3/29/18	TCR 009	0.18	1.23		
3/29/18	TCR 010	0.17	1.42		
3/29/18	TCR 011	0.09	1.36		
3/29/18	TCR 012	0.28	2.16		
3/29/18	TCR 013	0.12	1.22		
3/29/18	TCR 014	0.17	1.82		
3/29/18	TCR 015	0.1	0.76		
3/29/18	TCR 016	0.35	2.34		
3/29/18	TCR 017	0.2	2.49		
3/29/18	ACR 018	0.24	2.01		
3/29/18	ACR 019	0.25	2.42		
3/29/18	ACR 020	0.67	2.55		
3/30/18	POE 001	0.26	2.74		
3/30/18	MRT 002	0.22	2.12		

3/30/18	POE 003	0.26	2.47		
3/30/18	TCR 004	0.21	2.06		
3/30/18	TCR 005	0.18	2.33		
3/30/18	TCR 006	0.1	0.95		
3/30/18	TCR 007	0.17	1.58		
3/30/18	TCR 008	0.15	2.21		
3/30/18	TCR 009	0.14	1.4		
3/30/18	TCR 010	0.19	1.25		
3/30/18	TCR 011	0.11	2.01		
3/30/18	TCR 012	0.26	2.09		
3/30/18	TCR 013	0.18	1.81		
3/30/18	TCR 014	0.1	1.93		
3/30/18	TCR 015	0.23	2.3		
3/30/18	TCR 016	0.29	2.12		
3/30/18	TCR 017	0.32	2.59		
3/30/18	ACR 018	0.23	2.14		
3/30/18	ACR 019	0.27	2.2		
3/30/18	ACR 020	0.3	2.78		
3/31/18	POE 001	0.18	2.78		
3/31/18	MRT 002	0.12	1.7		
3/31/18	POE 003	0.24	2.29		
3/31/18	TCR 004	0.21	2.19		
3/31/18	TCR 005	0.14	2.18		
3/31/18	TCR 006	0.14	2.36		
3/31/18	TCR 007	0.16	2.18		
3/31/18	TCR 008	0.18	2.19		
3/31/18	TCR 009	0.15	1.6		
3/31/18	TCR 010	0.1	1.23		
3/31/18	TCR 011	0.13	2.06		
3/31/18	TCR 012	0.24	2.26		
3/31/18	TCR 013	0.18	1.9		

3/31/18	TCR 014	0.16	2.1		
3/31/18	TCR 015	0.17	2.28		
3/31/18	TCR 016	0.18	2.19		
3/31/18	TCR 017	0.21	2.62		
3/31/18	ACR 018	0.17	2.24		
3/31/18	ACR 019	0.24	2.46		
3/31/18	ACR 020	0.26	2.68		
4/1/18	POE 001	0.16	2.88		
4/1/18	MRT 002	0.14	1.81		
4/1/18	POE 003	0.19	2.49		
4/1/18	TCR 004	0.23	2.2		
4/1/18	TCR 005	0.15	2.37		
4/1/18	TCR 006	0.13	2.2		
4/1/18	TCR 007	0.19	2.15		
4/1/18	TCR 008	0.2	2.3		
4/1/18	TCR 009	0.16	1.51		
4/1/18	TCR 010	0.09	1.12		
4/1/18	TCR 011	0.12	2.02		
4/1/18	TCR 012	0.27	2.3		
4/1/18	TCR 013	0.22	1.83		
4/1/18	TCR 014	0.15	2.08		
4/1/18	TCR 015	0.16	2.1		
4/1/18	TCR 016	0.17	2.26		
4/1/18	TCR 017	0.24	2.76		
4/1/18	ACR 018	0.18	2.24		
4/1/18	ACR 019	0.16	2.39		
4/1/18	ACR 020	0.28	2.98		