

Cross Gates Water System (PWS 1103053)

12.5% Sodium Hypochlorite

Steele Road Well Feed Rate: 170 ml/min

Willow Wood Well Feed Rate: 140 ml/min

Date	Sample Location	Free Chlorine (mg/L)	Total Chlorine (mg/L)	Monochloramine (mg/L)	Free Ammonia (mg/L)
4/2/18	POE 001	0	2.77	2.96	0
4/2/18	MRT 002	0.14	1.81	1.79	0.06
4/2/18	POE 003	0	2.44	2.49	0
4/2/18	TCR 004	0.31	2.43		
4/2/18	TCR 005	0.23	2.28		
4/2/18	TCR 006	0.3	2.39		
4/2/18	TCR 007	0.43	2.17		
4/2/18	TCR 008	0.32	2.31		
4/2/18	TCR 009	0.18	1.95		
4/2/18	TCR 010	0.16	1.09		
4/2/18	TCR 011	0.11	2.2		
4/2/18	TCR 012	0.3	2.17		
4/2/18	TCR 013	0.12	1.76		
4/2/18	TCR 014	0.07	2.06		
4/2/18	TCR 015	0.09	2.03		
4/2/18	TCR 016	0.24	2.28		
4/2/18	TCR 017	0.3	2.71		
4/2/18	ACR 018	0.16	1.94		
4/2/18	ACR 019	0.89	2.52		
4/2/18	ACR 020	0.23	2.68		
4/3/18	POE 001 - Steele Road Well	0.33	2.75		

4/3/18	MRT 002- 500 S. Military	0.28	1.87		
4/3/18	POE 003 - Willow Wood Well	0.43	2.38		
4/3/18	TCR 005 - 321 Autumn Lakes Rd	0.3	2.24		
4/3/18	TCR 006 - 1301 Bluff Dr	0.19	2.2		
4/3/18	TCR 008 - 500 Dockside	0.17	2.43		
4/3/18	TCR 010 - 226 Goldenwood Dr.	0.13	1.16		
4/3/18	TCR 013 - 40145 Taylor Trace	0.18	1.89		
4/3/18	TCR 016 - 870 Crossgates Blvd	0.4	2.32		
4/3/18	ACR 018 - 201 Leeds	0.21	2.37		
4/4/18	POE 001 - Steele Road Well	0.29	2.65		
4/4/18	MRT 002- 500 S. Military	0.18	1.84		
4/4/18	POE 003 - Willow Wood Well	0.27	2.47		
4/4/18	TCR 006 - 1301 Bluff Dr	0.16	2.12		
4/4/18	TCR 008 - 500 Dockside	0.23	2.23		
4/4/18	TCR 010 - 226 Goldenwood Dr.	0.12	1.16		
4/4/18	TCR 012 - 104 Dublin Ct	0.29	2.2		
4/4/18	TCR 013 - 40145 Taylor Trace	0.24	2		
4/4/18	TCR 016 - 870 Crossgates Blvd	0.3	2.27		
4/4/18	ACR 018 - 201 Leeds	0.29	2.18		
4/5/18	POE 001 - Steele Road Well	0.35	2.59		
4/5/18	MRT 002- 500 S. Military	0.25	1.84		
4/5/18	POE 003 - Willow Wood Well	0.26	2.46		
4/5/18	TCR 006 - 1301 Bluff Dr	0.19	2.02		
4/5/18	TCR 008 - 500 Dockside	0.2	1.88		
4/5/18	TCR 010 - 226 Goldenwood Dr.	0.17	1.05		
4/5/18	TCR 013 - 40145 Taylor Trace	0.2	1.65		
4/5/18	TCR 016 - 870 Crossgates Blvd	0.26	2.23		
4/5/18	ACR 018 - 201 Leeds	0.19	2.08		
4/6/18	POE 001 - Steele Road Well	0.38	2.71		
4/6/18	POE 003 - Willow Wood Well	0.31	2.57		

4/6/18	TCR 005 - 321 Autumn Lakes Rd	0.32	2.24		
4/6/18	TCR 006 - 1301 Bluff Dr	0.2	1.19		
4/6/18	TCR 007 - 1059 Parkpoint Dr	0.22	1.93		
4/6/18	TCR 008 - 500 Dockside	0.09	1.94		
4/6/18	TCR 010 - 226 Goldenwood Dr.	0.17	1.15		
4/6/18	TCR 013 - 40145 Taylor Trace	0.15	1.93		
4/6/18	TCR 016 - 870 Crossgates Blvd	0.23	2.07		
4/6/18	ACR 018 - 201 Leeds	0.21	2.09		
4/7/18	POE 001 - Steele Road Well	0.3	2.57		
4/7/18	POE 003 - Willow Wood Well	0.26	2.59		
4/7/18	TCR 005 - 321 Autumn Lakes Rd	0.24	1.98		
4/7/18	TCR 007 - 1059 Parkpoint Dr	0.24	1.75		
4/7/18	TCR 008 - 500 Dockside	0.19	2.02		
4/7/18	TCR 010 - 226 Goldenwood Dr.	0.16	1.1		
4/7/18	TCR 013 - 40145 Taylor Trace	0.27	2.14		
4/7/18	TCR 016 - 870 Crossgates Blvd	0.25	2.35		
4/7/18	ACR 018 - 201 Leeds	0.08	2.07		
4/8/18	POE 001 - Steele Road Well	0.39	2.65		
4/8/18	POE 003 - Willow Wood Well	0.37	2.7		
4/8/18	TCR 005 - 321 Autumn Lakes Rd	0.21	1.84		
4/8/18	TCR 007 - 1059 Parkpoint Dr	0.23	1.55		
4/8/18	TCR 008 - 500 Dockside	0.17	2.02		
4/8/18	TCR 010 - 226 Goldenwood Dr.	0.08	1.2		
4/8/18	TCR 013 - 40145 Taylor Trace	0.26	2.19		
4/8/18	TCR 016 - 870 Crossgates Blvd	0.27	2.37		
4/8/18	ACR 018 - 201 Leeds	0.11	2.1		