

Cross Gates Water System (PWS 1103053)

12.5% Sodium Hypochlorite

Steele Road Well Feed Rate: 170 ml/min

Willow Wood Well Feed Rate: 140 ml/min

Date	Sample Location	Free Chlorine (mg/L)	Total Chlorine (mg/L)	Monochloramine (mg/L)	Free Ammonia (mg/L)
4/9/18	POE 001 - Steele Road Well	0.53	2.89		
4/9/18	MRT 002- 500 S. Military	0.25	2.09		
4/9/18	POE 003 - Willow Wood Well	0.4	2.52		
4/9/18	TCR 005 - 321 Autumn Lakes Rd	0.32	2.03		
4/9/18	TCR 007 - 1059 Parkpoint Dr	0.21	1.55		
4/9/18	TCR 008 - 500 Dockside	0.27	2.55		
4/9/18	TCR 010 - 226 Goldenwood Dr.	0.15	1.76		
4/9/18	TCR 013 - 40145 Taylor Trace	0.19	2.18		
4/9/18	TCR 016 - 870 Crossgates Blvd	0.12	2.04		
4/9/18	ACR 018 - 201 Leeds	0.27	2.15		
4/10/18	POE 001 - Steele Road Well	0.12	3.03	3.03	0
4/10/18	MRT 002- 500 S. Military	0.16	2.2	2.17	0.04
4/10/18	POE 003 - Willow Wood Well	0.31	2.32	2.29	0.48
4/10/18	TCR 005 - 321 Autumn Lakes Rd	0.21	2.25		
4/10/18	TCR 007 - 1059 Parkpoint Dr	0.18	1.79		
4/10/18	TCR 008 - 500 Dockside	0.28	2.41		
4/10/18	TCR 010 - 226 Goldenwood Dr.	0.18	1.87		
4/10/18	TCR 013 - 40145 Taylor Trace	0.32	2.19		
4/10/18	TCR 016 - 870 Crossgates Blvd	0.14	2.29		
4/10/18	ACR 018 - 201 Leeds	0	2.22		
4/11/18	POE 001 - Steele Road Well	0.48	2.63		

4/11/18	MRT 002- 500 S. Military	0.22	2.17		
4/11/18	POE 003 - Willow Wood Well	0.04	2.68	2.56	0.01
4/11/18	TCR 005 - 321 Autumn Lakes Rd	0.37	2.57		
4/11/18	TCR 007 - 1059 Parkpoint Dr	0.26	1.77		
4/11/18	TCR 008 - 500 Dockside	0.21	2.45		
4/11/18	TCR 010 - 226 Goldenwood Dr.	0.19	1.8		
4/11/18	TCR 013 - 40145 Taylor Trace	0.31	2.12		
4/11/18	TCR 016 - 870 Crossgates Blvd	0.34	2.39		
4/11/18	ACR 018 - 201 Leeds	0.23	2.25		
4/12/18	POE 001 - Steele Road Well	0.54	2.73		
4/12/18	MRT 002- 500 S. Military	0.33	2.13		
4/12/18	POE 003 - Willow Wood Well	0.52	2.54		
4/12/18	TCR 005 - 321 Autumn Lakes Rd	0.53	2.56		
4/12/18	TCR 007 - 1059 Parkpoint Dr	0.21	1.45		
4/12/18	TCR 008 - 500 Dockside	0.22	2.38		
4/12/18	TCR 010 - 226 Goldenwood Dr.	0.19	1.69		
4/12/18	TCR 013 - 40145 Taylor Trace	0.19	2.06		
4/12/18	TCR 016 - 870 Crossgates Blvd	0.31	2.45		
4/12/18	ACR 018 - 201 Leeds	0.2	2.18		
4/13/18	POE 001 - Steele Road Well	0.45	2.87		
4/13/18	MRT 002- 500 S. Military	0.18	2.12		
4/13/18	POE 003 - Willow Wood Well	0.3	2.53		
4/13/18	TCR 005 - 321 Autumn Lakes Rd	0.24	2.5		
4/13/18	TCR 007 - 1059 Parkpoint Dr	0.24	1.64		
4/13/18	TCR 008 - 500 Dockside	0.32	2.32		
4/13/18	TCR 010 - 226 Goldenwood Dr.	0.19	1.57		
4/13/18	TCR 013 - 40145 Taylor Trace	0.23	2.09		
4/13/18	TCR 016 - 870 Crossgates Blvd	0.22	2.49		
4/13/18	ACR 018 - 201 Leeds	0.26	2.31		
4/14/18	POE 001 - Steele Road Well	0.31	2.98		

4/14/18	MRT 002- 500 S. Military	0.24	2.19		
4/14/18	POE 003 - Willow Wood Well	0.02	2.69		
4/14/18	TCR 005 - 321 Autumn Lakes Rd	0.19	2.21		
4/14/18	TCR 007 - 1059 Parkpoint Dr	0.21	2.24		
4/14/18	TCR 008 - 500 Dockside	0.16	2.18		
4/14/18	TCR 010 - 226 Goldenwood Dr.	0.18	1.4		
4/14/18	TCR 013 - 40145 Taylor Trace	0.26	2.15		
4/14/18	TCR 016 - 870 Crossgates Blvd	0.32	2.36		
4/14/18	ACR 018 - 201 Leeds	0.19	2.21		
4/15/18	POE 001 - Steele Road Well	0.27	2.52		
4/15/18	MRT 002- 500 S. Military	0.22	1.98		
4/15/18	POE 003 - Willow Wood Well	0.21	2.24		
4/15/18	TCR 005 - 321 Autumn Lakes Rd	0.2	2.24		
4/15/18	TCR 007 - 1059 Parkpoint Dr	0.19	2.26		
4/15/18	TCR 008 - 500 Dockside	0.18	2.28		
4/15/18	TCR 010 - 226 Goldenwood Dr.	0.21	1.58		
4/15/18	TCR 013 - 40145 Taylor Trace	0.12	2.15		
4/15/18	TCR 016 - 870 Crossgates Blvd	0.19	2.13		
4/15/18	ACR 018 - 201 Leeds	0.2	2.19		
4/16/18	POE 001 - Steele Road Well	0.44	2.93		
4/16/18	MRT 002- 500 S. Military	0.1	1.82		
4/16/18	POE 003 - Willow Wood Well	0.19	1.99		
4/16/18	TCR 005 - 321 Autumn Lakes Rd	0.42	2.65		
4/16/18	TCR 007 - 1059 Parkpoint Dr	0.28	1.41		
4/16/18	TCR 008 - 500 Dockside	0.1	2.14		
4/16/18	TCR 010 - 226 Goldenwood Dr.	0.12	1.87		
4/16/18	TCR 013 - 40145 Taylor Trace	0.25	2.2		
4/16/18	TCR 016 - 870 Crossgates Blvd	0.21	2.49		
4/16/18	ACR 018 - 201 Leeds	0.43	2.6		

