



M.J. "Mike" Foster, Jr  
GOVERNOR

STATE OF LOUISIANA  
DEPARTMENT OF HEALTH AND HOSPITALS



David W. Hood  
SECRETARY

### STEPS TO DISINFECT WELLS

1. Introduce 1-2 gallons of bleach into the well at the "Well Head" followed by at least 15 gallons of **CLEAN WATER**.
2. Allow the disinfectant to stand for at least 1 hour.
3. Open every faucet in the system and let the water run until the smell of chlorine can be detected. Then close all of the faucets.
4. Let stand for at least 8-12 hours and then open the water taps and flush until the odor of chlorine is gone.

NOTE: The longer the chlorine is in contact with the pipes the better the disinfection

### TYPICAL DOMESTIC WELL SET-UP

